



दिल्ली मेट्रो रेल कॉर्पोरेशन लि० DELHI METRO RAIL CORPORATION LTD.

(भारत सरकार एवं दिल्ली सरकार का एक संयुक्त उपक्रम)
(A JOINT VENTURE OF GOVERNMENT OF INDIA AND GOVT. OF DELHI)

No. DMRC/Corp/20/Design/001/99/Vol. X

January 20, 2010

M/s SRMB Srijan Limited,
SRMB House,
7 Khetra Das Lane,
Kolkata – 700 012

Kind Attn. Mr. Ashish Beriwal, Director (Overseas Operation & Business Dev.)

Sub:- Approval for SRMB Product (Zinga) for use in Delhi Metro Rail Projects..

Sir,

With reference to your request letter, national and international test reports, journals in regard to your cold film galvanization coating your organization was requested to provide detailed technical presentation at our office. A close review of the facts presented in your technical documents and your presentation we would like to mention that we don't have any objection in case your product is used for the following applications:-

1. Zinga coating may be considered as precoating application for rebars used in RCC works in metro projects near coastal areas and earthquake prone zones with the permission of the client.
2. Since your organization is giving unique corrosion guarantee for coating on exposed metallic structures, zinga may be preferred over other paints and coating. Necessary cost benefit analysis may be needed to be provided by your company in this regard to the approving authority before the same is considered to be entered in technical specifications.
3. It has also been noted from the RDSO Report No. MC-136, June, 2009 as submitted to this office alongwith international references that Zinga can be used as anti corrosive coating for the following applications:-

- a) Zinga coating may be used as a protective coating for rails.
- b) Zinga coating may be used as a interior wagon coating & as a part of duplex coating for exterior coating on wagons.
- c) Zinga coating can be used for under frames of carriages, wagons, locomotives for long life corrosion protection.
- d) Zinga coating can be used in bridges as along life coating in all corrosive regions.
- e) Zinga coating may be used in electrical installation structures.

This **"No Objection/Approval"** is being accorded to you based on RDSO Report and International references.

The above "No Objection/Approval", however, does not bind the Corporation in anyway for use of your product /products in the works.

Thanking you,

Yours sincerely,



(Rajan Kataria)
Chief Engineer/Design